



CHS Controls AB
Tel +46 42 38 61 00, Fax +46 42 38 61 29
chs@chscontrols.se www.chscontrols.se



CHEKVOLT® (R-3MT-VI-DC2 & R-3MT-VI-DC3)

INSTALLATION GUIDE & OPERATING INSTRUCTIONS

Non-Hazardous Locations		
Indoor	Indoor/Outdoor	Ingress Protection
UL Type 12, 13	UL Type 4, 4X	IP2X, IP66, IP69
Approvals		
CSA C22.2 No. 94.2/ UL 50E	UL 61010-1 3rd Ed. with AMD 1	CAT III 1000V
CAT IV 600V	CE	UL/CSA 61010-2-030 2nd Ed.
EN 61010-2-030 2nd Ed.		

For technical questions call 1-800-280-9517 and select Option 3 for Technical Support when prompted

Grace Technologies, Inc. • 1515 E Kimberly Road • Davenport, Iowa 52807
Phone: 1-800-280-9517 • **Fax:** (563)386-9639 • www.pesd.com



CHS Controls AB
Tel +46 42 38 61 00, Fax +46 42 38 61 29
chs@chscontrols.se www.chscontrols.se



ChekVolt® is a combination device used to verify the voltage presence using visual indication and absence through a metered test.

SPECIFICATIONS


DC Voltage or Stored Energy Range	Test Point: 0 - 1000VDC any (2) wires Voltage Indicator: 20 - 1000VDC Voltages Line-to-Line or Line-to-Ground
Maximum Voltage	1000VDC
Maximum Power Consumption	Test Point: 3 Watts @ 1000V (approx.) with fault load of any (2) corresponding test points shorted indefinitely Voltage Indicator: 2.1 Watts
Temperatures	Operate: -20°C to +55°C Storage: -45°C to +85°C
Failure Current	Maximum single component failure fault current at 1000V Test Point: 3.2mA with a momentary short between any (2) test points Voltage Indicator: 3.7mA with any (1) line input series power resistor shorted
Internal Resistance	Test Point: (2) 82K 3W 5% Tolerance series resistors encapsulated between each input wire and respective test point (164KΩ 6W equivalent between any two test points)
Output Accuracy	-3.2% of applied voltage with 10M Ω input impedance voltmeter connected to any (2) test points
Terminations	2-Wire: (2) Wires, 8 ft, 14 AWG, 90°C @ 1000V, UL-1452, insulated Nylon jacket 3-Wire: (3) Wires, 8 ft, 14 AWG, 90°C @ 1000V, UL-1452, insulated Nylon jacket
Voltage Category Ratings	CAT III @ 1000VAC Max, Pollution Degree 3, CAT IV @ 600 VAC Max, pollution Degree 3
Housing	UL Approved material, totally encapsulated including LEDs for environmental protection
Indicators	2-Wire: (4) Red {L1, L2}, Super Bright LEDs 3-Wire: (4) Red {L1, L2} and (2) Yellow {GND}, Super Bright LEDs

Note: All above ratings are LINE-TO-LINE or LINE-TO-NEUTRAL (3-wire)



UL Type 4, 4X,
12, 13, IP2X,
IP66, IP69,

R-3MT-VI-DC2 WIRE IDENTIFICATION



R-3MT-VI-DC3 WIRE IDENTIFICATION



Caution



Caution, possibility of electrical shock



CHS Controls AB

Tel +46 42 38 61 00, Fax +46 42 38 61 29

chs@chscontrols.se www.chscontrols.se



⚠ BE SURE POWER IS SHUT OFF PRIOR TO INSTALLING THIS DEVICE.

⚠ CAUTION

- Location of device and internal hardware/wiring MUST allow free operation of ON/OFF disconnect mean.
- Means of anti-rotation is optional (see knock-out *Fig. 1* for one or more tab locations).
- The O-ring material is FVMQ fluorosilicone. Please refer to a Chemical Compatibility chart for your application(s).
- Maximum single component failure fault current is 3.2mA @ 1000VDC with a momentary short between any (2) test points.
- Do not operate above 1000VDC @ 55°C ambient or >2000m altitude or >80% RH (Relative Humidity).
- If this product is used in a manner not herein prescribed, the protection provided may be impaired.
- PESD conductors must be protected over their entire length from damage to conductor insulation that would cause a short circuit to occur. Please refer to the protection methods outlined in Paragraphs 29.4.2 and 29.4.4. b) of UL 508A.

⚠ WARNING Use of an Overcurrent Protection Device or Fuse is “NOT RECOMMENDED” when installing these devices in safety applications for verifying both voltage presence and voltage absence condition. A blown fuse or a tripped circuit breaker connected in line with this device could potentially lead to a false negative indication of voltage which is otherwise present. This device has been tested as equivalent to overcurrent protection for the application of tap conductor requirements.

⚠ WARNING Cancer - Reproductive Harm. This product can expose you to chemicals which are known to the state of California to cause cancer, birth defects or other reproductive harm. For more information, go to: www.P65Warnings.ca.gov



INSTALLATION INSTRUCTIONS

1. Follow all Local, State, and National Electrical Codes when installing this equipment. Overcurrent protection is not recommended. If device leads are either extended beyond the supplied length or the device installation extends beyond the enclosure where the leads are terminated, overcurrent protection of the supply leads may be required by Local, State or National Electric Codes. The installation of overcurrent protection shall be in accordance with the requirements in the NEC (NFPA 70) or end product standard(s) when used in final installation.
2. Locate the unit in visual proximity to the control panel ON/OFF disconnect and within wiring distance to incoming DC Power Lines and ground conductor. Mount the unit through a 30.5 mm knockout hole on the three-phase control panel to be monitored. To meet Type 12, 13, 4, or 4X sealing requirements, mount with supplied cap on a clean flat surface or inside a Type 4 or 4X housing. (Fig. 1)
3. With the PESD unit installed, wired, and the enclosure closed, verify the power disconnect is OFF.
4. Using the proper test equipment: the voltmeter should be rated for Cat III/1000V and Cat IV/1000V. Test probes should be fully insulated with .080" DIA points to insert into test point jacks.
5. Follow all safety and lock-out/Tag-out (LOTO) procedures. Set voltmeter to DCV, Verify zero voltage between either (2) test point combination {L+ to L-} or (3) test point combinations {L+ to L-, L+ to N, L- to N}.
6. STORED ENERGY is present whenever DCV readings are observed. The energy must be removed or discharged before the enclosure is to be opened or electrician work is to be performed.
7. Remove any unsafe load conditions and notify personnel power is about to be restored. Follow facility and equipment procedures for restoring power.
8. Repeat step 5 measurements but now verify proper operating voltage conditions appear on the Test Point combinations.

Note: For greater accuracy, multiply voltmeter reading by a factor of 1.03 to determine actual line voltage.)



OPERATION INSTRUCTIONS

Equipment needed: Digital voltmeter with 1000V AC or 1000V DC rated input minimum, 10MΩ input impedance and CAT III & IV. A pair of insulated test probes with .080" DIA. points.

Directions: Before and after each test, determine the voltmeter is operating satisfactorily through verification of known DC voltage sources. With the meter switched to VDC and test leads in DCV meter jacks, a qualified person can insert probe points into posts {L+, L-}.

1. To validate normal powered conditions, DC voltage is observed for circuits {L+, L-}.
2. To check for zero electrical energy during shut off, verify sources of feedback or stored energy are first neutralized. With the meter and leads setup for VDC measurement, verify the circuits above are de-energized.
3. Ensure your facility personnel are properly trained with the use and limitations of these devices and properly update the "Point of Connections" on your installation drawings.

WARNING

BEFORE OPENING A PANEL, TURN POWER OFF! SAFETY PROCEDURES STILL APPLY!

Before working on an electrical conductor, verify zero electrical energy with proper voltage testing instrument and the proper procedure as per NFPA 70E 120.1(5), 120.2 (F)(2)(f)(1-6), OSHA 1910.333(b)(2)(iv)(B)."

AVANT D'OUVRIR UN PANNEAU ÉLECTRIQUE, COUPER L'ALIMENTATION! LES PROCÉDURES DE SÉCURITÉ S'APPLIQUENT TOUJOURS! Avant d'effectuer des travaux sur un conducteur électrique, vérifier que le courant est coupé à l'aide d'un instrument de mesure de tension approprié en suivant la procédure adéquate, selon les normes de la NFPA (National Fire Protection Association) 70E 120.1(5), 120.2 (F)(2)(f)(1-6), de l'OSHA (Occupational Safety and Health Administration) 1910.333(b)(2)(iv)(B).

MAINTENANCE

With power removed, free dust and particles from the front of the label and dust cap with compressed air. Open the dust cap by unscrewing the cap screw and free the dust and particles on the inside of the cap and jack sockets with compressed air. Maintain a clean label by gently wiping with a clean damp cloth while power is removed. Cleaning while powered is not recommended.



MEASUREMENT CATEGORY

The categories take into account the total continuous energy available at the given point of circuit, and the occurrence of impulse voltages. The energy can be limited by circuit breakers or fuses, and the impulse voltages by the nominal level of voltage. Maximum rated voltage of this device is 1000VDC.

CAT III is for circuits which can be connected to the mains installation of a building. Energy is limited by circuit breakers to less than 110 000VA with the current not exceeding 11 000A.

CAT IV includes circuits which are connected directly to the source of power for a given building. There are very high levels of available energy (e.g. limited only by the power transformer) and arc flash can occur.




CHS Controls AB
Tel +46 42 38 61 00, Fax +46 42 38 61 29
chs@chscontrols.se www.chscontrols.se




Included in R-3MT-VI-DC2-KIT:



ChekVolt® with Cap
(R-3MT-VI-DC2 & R-PESD-CAP)



Horizontal Label*
(R-3MT-VI-DC2-LH)



Flange Label*
(R-3MT-VI-DC2-LF)

**Both the Horizontal and Flange labels are included in your kit. Use the appropriate label per your installation requirements.*
Custom labels are available upon request. Please call 1-800-280-9517 or visit www.pesd.com



CHS Controls AB

Tel +46 42 38 61 00, Fax +46 42 38 61 29


chs@chscontrols.se www.chscontrols.se




Included in R-3MT-VI-DC3-KIT:



ChekVolt® with Cap
(R-3MT-VI-DC3 & R-PESD-CAP)



Horizontal Label*
(R-3MT-VI-DC3-LH)



Flange Label*
(R-3MT-VI-DC3-LF)

**Both the Horizontal and Flange labels are included in your kit. Use the appropriate label per your installation requirements. Custom labels are available upon request. Please call 1-800-280-9517 or visit www.pesd.com*



Figure 1





Figure 2



Note: Face label artwork shown above may differ based on specific unit purchased. (4) Test point jacks accept .080" DIA. probe points. Use abrasion and cut resistant wire sleeves to route the device leads to protect against mechanical damage resulting from sharp edges and door hinges.



Figure 3

(DC3) SINGLE SOURCE, 2-Wire ONLY




Figure 4

(DC3) SINGLE SOURCE, 2-Wire + N REDUNDANT APPLICATION

